

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
SGFM 001-SCIENCE RM. 2-8 (SINK)	10/1/2016 06:01	10/17/2016 23:55	10366024001	Lead	2.9	15	ug/L
SGFM 002-SCIENCE RM. 2-8 (SINK)	10/1/2016 06:05	10/17/2016 23:59	10366024002	Lead	0.47	15	ug/L
SGFM 003-SCIENCE RM. 2-8 (SINK)	10/1/2016 06:07	10/18/2016 00:03	10366024003	Lead	1.2	15	ug/L
SGFM 004-SCIENCE RM. 2-8 (SINK)	10/1/2016 06:08	10/18/2016 00:04	10366024004	Lead	0.69	15	ug/L
SGFM 005-SCIENCE RM. 2-8 (SINK)	10/1/2016 06:10	10/18/2016 00:05	10366024005	Lead	52.0	15	ug/L
SGFM 006-MAIN OFFICE "KITCHEN"	10/1/2016 06:10	10/18/2016 00:06	10366024006	Lead	109	15	ug/L
SGFM 007-MAIN OFFICE "BATHROOM"	10/1/2016 06:10	10/18/2016 00:08	10366024007	Lead	4.1	15	ug/L
SGFM 008-GUIDENCE "BATHROOM"	10/1/2016 06:12	10/21/2016 11:17	10366024008	Lead	0.68	15	ug/L
SGFM 009-GUIDENCE (SINK)	10/1/2016 06:15	10/18/2016 00:09	10366024009	Lead	3.7	15	ug/L
SGFM 010-SCIENCE RM 2-10 (SINK)	10/1/2016 06:16	10/18/2016 00:10	10366024010	Lead	0.49	15	ug/L
SGFM 011-SCIENCE RM 2-10 (SINK)	10/1/2016 06:16	10/18/2016 00:11	10366024011	Lead	0.44	15	ug/L
SGFM 012-SCIENCE RM 2-10 (SINK)	10/1/2016 06:18	10/18/2016 00:12	10366024012	Lead	0.79	15	ug/L
SGFM 013-SCIENCE RM 2-8 (SINK)	10/1/2016 06:18	10/18/2016 00:17	10366024013	Lead	0.12	15	ug/L
SGFM 014-SCIENCE RM 2-8 (SINK)	10/1/2016 06:19	10/18/2016 00:18	10366024014	Lead	1.0	15	ug/L
SGFM 015-SCIENCE RM 2-8 "OFFICE"	10/1/2016 06:20	10/18/2016 00:20	10366024015	Lead	0.59	15	ug/L
SGFM 016-(WATER FOUNTAIN) #1	10/1/2016 06:23	10/18/2016 00:21	10366024016	Lead	1.7	15	ug/L
SGFM 017-FAUCETS-WOMEN "BATHROOM"	10/1/2016 06:30	10/18/2016 00:22	10366024017	Lead	0.65	15	ug/L
SGFM 018-FAUCETS-MEN "BATHROOM"	10/1/2016 06:31	10/18/2016 00:23	10366024018	Lead	0.35	15	ug/L
SGFM 019-CUSTODIAL CLOSET #1	10/1/2016 06:34	10/18/2016 00:24	10366024019	Lead	0.89	15	ug/L
SGFM 020-(WATER FOUNTAIN) #2	10/1/2016 06:35	10/18/2016 00:26	10366024020	Lead	0.52	15	ug/L

SGFM 021-GIRLS LOCKER RM "OFFICE"	10/1/2016 06:41	10/17/2016 21: 10	10366024021	Lead	0.2	15	ug/L
SGFM 022-GIRLS LOCKER RM (SINK)	10/1/2016 06:41	10/17/2016 21: 15	10366024022	Lead	0.39	15	ug/L
SGFM 023-GIRLS LOCKER RM (SINK)	10/1/2016 06:42	10/17/2016 21: 16	10366024023	Lead	0.59	15	ug/L
SGFM 024-GIRLS LOCKER RM (SINK)	10/1/2016 06:42	10/17/2016 21: 17	10366024024	Lead	10.9	15	ug/L
SGFM 025-GIRLS LOCKER ROOM "COACH'S OFFICE"	10/1/2016 06:44	10/17/2016 21: 18	10366024025	Lead	0.48	15	ug/L
SGFM 026-BOYS LOCKER RM "OFFICE"	10/1/2016 06:45	10/17/2016 21: 19	10366024026	Lead	0.39	15	ug/L
SGFM 027-BOYS LOCKER RM (SINK)	10/1/2016 06:46	10/17/2016 21: 21	10366024027	Lead	0.94	15	ug/L
SGFM 028-BOYS LOCKER RM (SINK)	10/1/2016 06:46	10/17/2016 21: 24	10366024028	Lead	8.0	15	ug/L
SGFM 029-BOYS LOCKER RM "COACH'S OFFICE"	10/1/2016 06:48	10/17/2016 21: 25	10366024029	Lead	0.34	15	ug/L
SGFM 030-(WATER FOUNTAIN) #3	10/1/2016 06:50	10/17/2016 21: 27	10366024030	Lead	0.81	15	ug/L
SGFM 031-GIRLS BATH RM #1 (WASHROOM)	10/1/2016 06:55	10/17/2016 21: 28	10366024031	Lead	0.83	15	ug/L
SGFM 032-GIRLS BATH RM #1 (WASHROOM)	10/1/2016 06:55	10/17/2016 21: 30	10366024032	Lead	14.7	15	ug/L
SGFM 033-GIRLS BATH RM #1 (WASHROOM)	10/1/2016 06:55	10/17/2016 21: 31	10366024033	Lead	5.2	15	ug/L
SGFM 034-BOYS BATH RM #1 (WASHROOM)	10/1/2016 06:58	10/17/2016 21: 33	10366024034	Lead	1.4	15	ug/L
SGFM 035-BOYS BATH RM #1 (WASHROOM)	10/1/2016 06:58	10/17/2016 21: 34	10366024035	Lead	1.7	15	ug/L
SGFM 036-BOYS BATH RM #1 (WASHROOM)	10/1/2016 06:59	10/17/2016 21: 35	10366024036	Lead	30.3	15	ug/L
SGFM 037-(WATER FOUNTAIN) #4	10/1/2016 07:02	10/17/2016 21: 39	10366024037	Lead	2.7	15	ug/L
SGFM 038-CUSTODIAL CLOSET #2	10/1/2016 07:04	10/17/2016 21: 40	10366024038	Lead	9.7	15	ug/L
SGFM 039-ICE/STORAGE RM (SINK)	10/1/2016 07:10	10/17/2016 21: 41	10366024039	Lead	3.1	15	ug/L
SGFM 040-ICE MACHINE (ICE)	10/1/2016 07:10	10/17/2016 21: 42	10366024040	Lead	2.8	15	ug/L
SGFM 041-CONCESSION STAND RM	10/1/2016 07:11	10/17/2016 19: 53	10366024041	Lead	3.8	15	ug/L

SGFM 042-ART RM 8-3 (SINK) #1	10/1/2016 07:15	10/17/2016 20:00	10366024042	Lead	2.5	15	ug/L
SGFM 043-ART RM 8-3 (SINK) #2	10/1/2016 07:15	10/17/2016 20:01	10366024043	Lead	6.5	15	ug/L
SGFM 044-ART RM 8-3 (SINK) #3	10/1/2016 07:16	10/17/2016 20:02	10366024044	Lead	5.7	15	ug/L
SGFM 045-ART RM 8-3 (SINK) #4	10/1/2016 07:16	10/17/2016 20:03	10366024045	Lead	5.2	15	ug/L
SGFM 046-ART RM 8-5 (SINK) #1	10/1/2016 07:17	10/17/2016 20:05	10366024046	Lead	3.0	15	ug/L
SGFM 047-ART RM 8-5 (SINK) #2	10/1/2016 07:18	10/17/2016 20:06	10366024047	Lead	10.2	15	ug/L
SGFM 048-ART RM 8-6 (SINK)	10/1/2016 07:22	10/17/2016 20:07	10366024048	Lead	5.9	15	ug/L
SGFM 049-GIRLS BATH RM #1 (WASHROOM)	10/1/2016 07:25	10/17/2016 20:11	10366024049	Lead	14.3	15	ug/L
SGFM 050-GIRLS BATH RM #1 (WASHROOM)	10/1/2016 07:25	10/17/2016 20:12	10366024050	Lead	6.0	15	ug/L
SGFM 051-BOYS BATH RM #1 (WASHROOM)	10/1/2016 07:27	10/17/2016 20:13	10366024051	Lead	0.57	15	ug/L
SGFM 052-BOYS BATH RM #1 (WASHROOM)	10/1/2016 07:27	10/17/2016 20:16	10366024052	Lead	1.1	15	ug/L
SGFM 053-BOYS BATH RM #1 (WASHROOM)	10/1/2016 07:28	10/17/2016 20:17	10366024053	Lead	1.0	15	ug/L
SGFM 054-SCIENCE RM 6-9 (SINK)	10/1/2016 07:35	10/17/2016 20:18	10366024054	Lead	0.36	15	ug/L
SGFM 055-SCIENCE RM 6-9 (SINK)	10/1/2016 07:36	10/17/2016 20:19	10366024055	Lead	0.12	15	ug/L
SGFM 056-SCIENCE RM 6-9 (SINK)	10/1/2016 07:37	10/17/2016 20:21	10366024056	Lead	0.85	15	ug/L
SGFM 057-SCIENCE RM 6-9 (SINK)	10/1/2016 07:38	10/17/2016 20:22	10366024057	Lead	0.2	15	ug/L
SGFM 058-SCIENCE RM 6-9 (SINK)	10/1/2016 07:39	10/17/2016 20:25	10366024058	Lead	4.7	15	ug/L
SGFM 059-SCIENCE RM 6-9 "STOR	10/1/2016 07:41	10/17/2016 20:27	10366024059	Lead	0.5	15	ug/L
SGFM 060-SCIENCE RM 6-8 (SINK)	10/1/2016 07:45	10/17/2016 20:28	10366024060	Lead	2.2	15	ug/L
SGFM 061-SCIENCE RM 6-8 (SINK)	10/1/2016 07:45	10/17/2016 22:17	10366024061	Lead	0.32	15	ug/L
SGFM 062-SCIENCE RM 6-8 (SINK)	10/1/2016 07:46	10/17/2016 22:24	10366024062	Lead	0.47	15	ug/L

SGFM 063-SCIENCE RM 6-8 (SINK)	10/1/2016 07:47	10/17/2016 22: 26	10366024063	Lead	1.7	15	ug/L
SGFM 064-SCIENCE RM 6-8 (SINK)	10/1/2016 07:48	10/17/2016 22: 27	10366024064	Lead	2.0	15	ug/L
SGFM 065-(WATER FOUNTAIN) #5	10/1/2016 07:51	10/17/2016 22: 28	10366024065	Lead	0.27	15	ug/L
SGFM 066-SCIENCE RM 6-1 (SINK)	10/1/2016 08:00	10/17/2016 22: 29	10366024066	Lead	0.61	15	ug/L
SGFM 067-SCIENCE RM 6-1 (SINK)	10/1/2016 08:00	10/17/2016 22: 30	10366024067	Lead	0.31	15	ug/L
SGFM 068-SCIENCE RM 6-1 (SINK)	10/1/2016 08:01	10/17/2016 22: 32	10366024068	Lead	0.46	15	ug/L
SGFM 069-SCIENCE RM 6-1 (SINK)	10/1/2016 08:02	10/17/2016 22: 33	10366024069	Lead	0.15	15	ug/L
SGFM 070-SCIENCE RM 6-1 (SINK)	10/1/2016 08:03	10/17/2016 22: 36	10366024070	Lead	0.56	15	ug/L
SGFM 071-SCIENCE RM 6-1 (SINK)	10/1/2016 08:04	10/17/2016 22: 38	10366024071	Lead	0.19	15	ug/L
SGFM 072-SCIENCE RM 6-2 (SINK)	10/1/2016 08:06	10/17/2016 22: 40	10366024072	Lead	0.72	15	ug/L
SGFM 073-SCIENCE RM 6-2 (SINK)	10/1/2016 08:06	10/17/2016 22: 41	10366024073	Lead	0.21	15	ug/L
SGFM 074-SCIENCE RM 6-2 (SINK)	10/1/2016 08:06	10/17/2016 22: 42	10366024074	Lead	0.69	15	ug/L
SGFM 075-SCIENCE RM 6-2 (SINK)	10/1/2016 08:07	10/17/2016 22: 44	10366024075	Lead	0.31	15	ug/L
SGFM 076-SCIENCE RM 6-2 (SINK)	10/1/2016 08:07	10/17/2016 22: 45	10366024076	Lead	1.1	15	ug/L
SGFM 077-SCIENCE RM 6-2 (SINK)	10/1/2016 08:08	10/17/2016 22: 46	10366024077	Lead	0.35	15	ug/L
SGFM 078-SCIENCE RM 6-2 (SINK)	10/1/2016 08:09	10/17/2016 22: 47	10366024078	Lead	1.6	15	ug/L
SGFM 079-GIRLS BATH RM #2 (SINK)	10/1/2016 08:09	10/17/2016 22: 51	10366024079	Lead	0.15	15	ug/L
SGFM 080-GIRLS BATH RM #2 (SINK)	10/1/2016 08:11	10/17/2016 22: 52	10366024080	Lead	6.0	15	ug/L
SGFM 081-GIRLS BATH RM #2 (SINK)	10/1/2016 08:12	10/19/2016 17: 34	10366024081	Lead	14.7	15	ug/L
SGFM 082-BOYS BATH RM #2 (SINK)	10/1/2016 08:12	10/19/2016 17: 39	10366024082	Lead	5.2	15	ug/L
SGFM 083-BOYS BATH RM #2 (SINK)	10/1/2016 08:13	10/21/2016 12: 39	10366024083	Lead	3.4	15	ug/L

SGFM 084-(WATER FOUNTAIN) #6	10/1/2016 08:15	10/21/2016 12: 40	10366024084	Lead	<0.10	15	ug/L
SGFM 085-ZIBBART RM 9-2 (SINK)	10/1/2016 08:17	10/21/2016 12: 49	10366024085	Lead	1.7	15	ug/L
SGFM 086-CUSTODIAL CLOSET #3	10/1/2016 08:18	10/21/2016 12: 50	10366024086	Lead	1.2	15	ug/L
SGFM 087-SCIENCE RM 6-4 (SINK)	10/1/2016 08:20	10/21/2016 12: 51	10366024087	Lead	13.4	15	ug/L
SGFM 088-SCIENCE RM 6-4 (SINK)	10/1/2016 08:20	10/21/2016 12: 52	10366024088	Lead	3.8	15	ug/L
SGFM 089-SCIENCE RM 6-4 (SINK)	10/1/2016 08:21	10/21/2016 12: 53	10366024089	Lead	13.1	15	ug/L
SGFM 090-SCIENCE RM 6-4 (SINK)	10/1/2016 08:22	10/21/2016 12: 55	10366024090	Lead	36.6	15	ug/L
SGFM 091-SCIENCE RM 6-4 (SINK)	10/1/2016 08:23	10/21/2016 12: 56	10366024091	Lead	16.1	15	ug/L
SGFM 092-SCIENCE RM 6-4 (SINK)	10/1/2016 08:23	10/21/2016 12: 57	10366024092	Lead	41.7	15	ug/L
SGFM 093-SCIENCE RM 6-4 (SINK)	10/1/2016 08:24	10/21/2016 12: 59	10366024093	Lead	24.3	15	ug/L
SGFM 094-BOYS BATH RM #3 (SINK)	10/1/2016 08:26	10/21/2016 13: 05	10366024094	Lead	1.6	15	ug/L
SGFM 095-GIRLS BATH RM #3 (SINK)	10/1/2016 08:27	10/26/2016 14: 09	10366024095	Lead	3.7	15	ug/L
SGFM 096-GIRLS BATH RM #3 (SINK)	10/1/2016 08:27	10/26/2016 14: 14	10366024096	Lead	12.2	15	ug/L
SGFM 097-NURSES OFFICE (SINK)	10/1/2016 08:31	10/21/2016 13: 06	10366024097	Lead	0.67	15	ug/L
SGFM 098-NURSES OFFICE "BATHROOM"	10/1/2016 08:32	10/21/2016 13: 07	10366024098	Lead	0.74	15	ug/L
SGFM 099-FACULTY LOUNGE (SINK)	10/1/2016 08:34	10/21/2016 13: 08	10366024099	Lead	2.5	15	ug/L
SGFM 100-FACULTY LOUNGE "WOMENS"	10/1/2016 08:35	10/21/2016 13: 09	10366024100	Lead	0.72	15	ug/L
SGFM 101-FACULTY LOUNGE "MENS"	10/1/2016 08:35	10/21/2016 13: 46	10366024101	Lead	0.7	15	ug/L
SGFM 102-(WATER FOUNTAIN) #7	10/1/2016 08:37	10/21/2016 13: 51	10366024102	Lead	5.8	15	ug/L
SGFM 103-HOME ED RM 3-5 (SINK)	10/1/2016 08:40	10/21/2016 13: 52	10366024103	Lead	1.3	15	ug/L
SGFM 104-HOME ED RM 3-5 (SINK)	10/1/2016 08:41	10/21/2016 13: 53	10366024104	Lead	2.5	15	ug/L

SGFM 105-HOME ED RM 3-5 (SINK)	10/1/2016 08:42	10/21/2016 13:54	10366024105	Lead	9.3	15	ug/L
SGFM 106-HOME ED RM 3-5 (SINK)	10/1/2016 08:43	10/21/2016 13:55	10366024106	Lead	2.4	15	ug/L
SGFM 107-HOME ED RM 3-5 (SINK)	10/1/2016 08:44	10/21/2016 13:59	10366024107	Lead	5.2	15	ug/L
SGFM 108-RM 3-6 (SINK)	10/1/2016 08:46	10/21/2016 14:00	10366024108	Lead	1.0	15	ug/L
SGFM 109-RM 3-6 "BATH RM" (SINK)	10/1/2016 08:47	10/21/2016 14:01	10366024109	Lead	4.5	15	ug/L
SGFM 110-GIRLS BATH RM #4 (SINK)	10/1/2016 08:50	10/21/2016 14:02	10366024110	Lead	2.6	15	ug/L
SGFM 111-GIRLS BATH RM #4 (SINK)	10/1/2016 08:50	10/21/2016 14:03	10366024111	Lead	2.8	15	ug/L
SGFM 112-GIRLS BATH RM #4 (SINK)	10/1/2016 08:51	10/21/2016 14:06	10366024112	Lead	3.1	15	ug/L
SGFM 113-GIRLS BATH RM #4 (SINK)	10/1/2016 08:52	10/21/2016 14:07	10366024113	Lead	3.7	15	ug/L
SGFM 114-BOYS BATH RM #4 (SINK)	10/1/2016 08:52	10/21/2016 14:08	10366024114	Lead	9.7	15	ug/L
SGFM 115-BOYS BATH RM #4 (SINK)	10/1/2016 08:53	10/21/2016 14:10	10366024115	Lead	17.4	15	ug/L
SGFM 116-(WATER FOUNTAIN) #8	10/1/2016 08:55	10/21/2016 14:15	10366024116	Lead	1.9	15	ug/L
SGFM 117-KITCHEN "CUSTODIAL CLOSET"	10/1/2016 08:57	10/21/2016 14:16	10366024117	Lead	0.79	15	ug/L
SGFM 118-KITCHEN "BATH RM"	10/1/2016 08:58	10/21/2016 14:18	10366024118	Lead	0.19	15	ug/L
SGFM 119-KITCHEN "HAND" (SINK)	10/1/2016 08:59	10/21/2016 14:19	10366024119	Lead	1.3	15	ug/L
SGFM 120-KITCHEN "DISH" (SINK)	10/1/2016 08:59	10/21/2016 14:20	10366024120	Lead	2.0	15	ug/L
SGFM 121-KITCHEN "DISH HOSE"	10/1/2016 09:04	10/21/2016 13:12	10366024121	Lead	0.18	15	ug/L
SGFM 122-KITCHEN "DISH" (SINK)	10/1/2016 09:05	10/21/2016 13:11	10366024122	Lead	0.67	15	ug/L
SGFM 123-KITCHEN "DISH" (SINK)	10/1/2016 09:06	10/21/2016 13:19	10366024123	Lead	1.5	15	ug/L
SGFM 124-KITCHEN "PREP" (SINK)	10/1/2016 09:07	10/21/2016 13:20	10366024124	Lead	3.4	15	ug/L
SGFM 125-KITCHEN "POT" (SINK)	10/1/2016 09:08	10/21/2016 13:21	10366024125	Lead	1.5	15	ug/L

SGFM 126-KITCHEN "POT HOSE"	10/1/2016 09:08	10/21/2016 13: 22	10366024126	Lead	0.64	15	ug/L
SGFM 127-KITCHEN "HAND" (SINK)	10/1/2016 09:10	10/21/2016 13: 23	10366024127	Lead	0.92	15	ug/L
SGFM 128-KITCHEN "PREP" (SINK)	10/1/2016 09:11	10/21/2016 13: 25	10366024128	Lead	0.5	15	ug/L
SGFM 129-KITCHEN "SQUARE KETTLE"	10/1/2016 09:13	10/21/2016 13: 26	10366024129	Lead	49.1	15	ug/L
SGFM 130-KITCHEN "ROUND KETTLE"	10/1/2016 09:13	10/21/2016 13: 27	10366024130	Lead	2.3	15	ug/L
SGFM 131-KITCHEN "ROUND KETTLE"	10/1/2016 09:13	10/21/2016 13: 31	10366024131	Lead	6.8	15	ug/L
SGFM 132-KITCHEN "ROUND KETTLE"	10/1/2016 09:15	10/21/2016 13: 34	10366024132	Lead	5.7	15	ug/L
SGFM 133-KITCHEN "ROUND KETTLE"	10/1/2016 09:16	10/21/2016 13: 35	10366024133	Lead	0.58	15	ug/L
SGFM 134-(WATER FOUNTAIN) #9	10/1/2016 09:17	10/21/2016 13: 36	10366024134	Lead	<0.10	15	ug/L
SGFM 135-BOYS RM CAFETERIA (SINK)	10/1/2016 09:20	10/21/2016 13: 37	10366024135	Lead	0.23	15	ug/L
SGFM 136-GIRLS RM CAFETERIA	10/1/2016 09:20	10/26/2016 14: 15	10366024136	Lead	0.74	15	ug/L
SGFM 137-CUSTODIAL CLOSET #4	10/1/2016 09:21	10/21/2016 13: 38	10366024137	Lead	39.3	15	ug/L

NYSDOH Action Level for Lead of 15 ppb

10 Positive

137 tested

Exterior faucets not listed were re-tested on November 8, 2016